

TECHNICAL SPECIFICATIONS

Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
1	Flat Panel Detector (FPD)			
1a	Atleast 14" x 17" in size			
1b	Detector Technology atleast Amorphouse Silicon			
1c	Sointillator atleast Csl			
1d	Pixels atleast 2304 x 2800			
1e	Conversion atleast 16 bit of higher			
1f	with a trigger mode atleast with AED and Software			
1g	Data interface atleast with Ethernet and WIFI(802.11ac)			
1h	Dimensions atleast 384mm x 460mm x 15mm (1mm)			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
1i	Weight atleast 3.3kg (without battery) and atleast 3.6kg (with battery)			
1j	Statis loading atleast 150kg uniformity			
1k	Battery capacity atleast 5 hours (full performance)			
1l	Casette-size flat panel detector			
1m	Should have installation and set-up			
1n	Atleast 1 year warrantly with service and maintenance (should atleast have 2-3 visits per year)			
1o	Provides Training and Demo for end-users (1-3 days)			
2	Ultrasonic Debridement Machine			
2a	Atleast with main voltage 230 V ± 10%			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
2b	50 Hz ± 5% switchable to 115 V ± 10%			
2c	60 Hz ± 5%, mains fuse 2 Asb (230 V)			
2d	4 Asb (115 V)			
2e	atleast with power consumption 250 VA, classification (as per mdd) 2b, protection class (as per en 60601-1) I			
2f	atleast frequency range 20 - 80 kHz			
2g	atleast output with handpiece detection 1			
2h	atleast vacuum aspiration 0 - 0.9 bar			
2i	atleast irrigation capacity 0 - 150 ml/min			
2j	infiltration capacity 0 - 250 ml/min			
2k	atleast unit dimensions w x h x d: 430 x 150 x 560 mm			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
2l	with atleast unit weight of 27.5 kg			
2m	with atleast trolley dimensions of w x h x d: 500 x 850 x 750 mm			
2n	atleast trolley weight of 12 kg			
2o	atleast trolley weight of 12 kg			
2p	with atleast Micro ENP handpiece 92-030 / Macro handpiece LUD 94-054			
2q	woth atleast Macro handpiece 94-106-HF			
2r	with atleast Micro Pen handpiece 94-106			
2s	with atelasr UAW (Ultrasound-Assisted Wound Treatment) handpieces 97-102, 97-103,			
3	ECG Machine			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
3a	atleast 1 - 3 channel printout format			
3b	atleast 190-200 × 60-70 graphic LCD to display atleast 1-3 Channel ECG waveform, setting menu and operating conditions of the unit			
3c	Rhythm lead with histogram and trend graph for R-R interval			
3d	Automatic measurement and interpretation of standard ECG parameter			
3e	Memory of atleast 85 exams for recall and duplication			
3f	Dual power operation, AC and Li-ion battery supporting atleast 2 hour operation			
3g	Paper size: atleast 50mmx20m, roll type			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
3h	Should supply the following accessories: 2 patient cable, eight clip on electrodes (thread type), 12 chest electrode with silicon rubber bulb, 24 packets of recording paper, 1 bottle of jelly			
3i	Should operate on mains (220v-50Hz) and rechargeable battery, and should have atleast 5-6 years full warranty			
4	Patient Monitor, 5 parameters			
4a	should be atleast water, chemical and shock proof			
4b	should be with atleast a color thin film transistor resistive touchscreen not more than 11 – 12.5 inches liquid crystal display			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
4c	should have atleast a display size selection of wide and high and with trace height option Resolution of not less than 1280 x 800 pixels			
4d	should atleast be capable of not less than 96 to 120 hours of graphic and tabular data trends			
4e	should have atleast two (2) pieces High frequency electrode, hook, with suction channel, 5 x 330 millimeters working length			
4f	With built-in hemodynamics and oxygen calculation			
4g	With built-in full view simultaneous display of 12 ECG leads			
4h	With built-in thermal array printer with a resolution of not less than eight dots vertical per millimeter and 32 dots horizontal per millimeter			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
4i	Built in printer speed of not less than 25 millimeters per second			
4j	Able to print manual and automatic alarm records for waveforms, vital signs, trends, calculations and full annotations Can record alarm parameters when alarm recording is activated			
4k	With alarm lights indicators based on the degree of severity which is displayed infront and back of the monitor for enhanced surveillance			
4l	Capable of invasive blood pressure monitoring			
4m	With Masimo technology pulse oximetry			
4n	With two (2) reusable skin surface temperature probe sensor of not less than 5-6 millimeters per monitor			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
4o	With one (1) reusable, latex free, waterproof, adult blood pressure cuffs, AHA & AAMI compliant, with high quality velcro per monitor			
4p	With two (2) reusable SpO2 finger sensor per monitor			
4q	With two (2) reusable, latex free, waterproof, pediatric blood pressure cuffs, AHA & AAMI compliant, with high quality Velcro per monitor			
4r	With two (2) ECG lead cables per monitor			
4s	With unit off and paper out indicator			
4t	With built-in rechargeable Lithium ion battery of not less than 5 hours of operation			
5	Suction Machine			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
5a	Volt- atleast 220-230 V			
5b	Rating of Motor - atleast continuous			
5c	Suction Bottle Capacity - atleast 2 x 2000 ml minimum (with safety valve)			
5d	Gauge - atleast 0 to 1000 mm Hg			
5e	Pump - Oil lubricates rotary pump			
5f	Should have air tight lids			
5g	Should have a noiseless Operation			
5h	Should provide filter to absorb moisture and water particles entering into the motor.			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
5i	Should have an external provision for topping up of lubricant, should have atleast 5-6 years full warranty.			
6	Electric Cast Cutter Set			
6a	design: atleast with an AC motor in a plastic body			
6b	dimensions: atleast 250-300mm in length , atleast 85-90mm in diameter			
6c	weight: atleast 1000-1800 g			
6d	motor: atleast 220-240 V, with input power of atleast 70-80W, 50/60Hz			
6e	temperature: atleast with an operating temperature +10 - 60 deg C (+50- +140 deg F)			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
6f	cutting: atleast with high-speed oscillating head with 10,000-15,000 oscillating angle of 5°			
6g	accessories: atleast with 2 pcs cutter blade 63-65mm			
6h	warranty and support: atleast with 1-3 years warranty, support tech and parts replacement			
6i	With Spare Cast Cutter Blade			
7	Emergency Cart			
7a	Emergency Trolley			
7b	Size: atleast 850x520x101 mm			
7c	atleast with 5 drawers (2 small, 2 middle, and 1 big)			
7e	atleast with 2 pcs garbage bin with lid and 1 pc transparent file case			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
7f	atleast with 1 I.V. pole and 1 pc tray			
7g	with atleast 5 inches castor with brake on the cross			
8	Stretcher			
8a	with an IV pole			
8b	stainless steel frame			
8c	adjustable head of bed to semi-fowlers position			
8d	with side rails			
8e	with artificial or foam mattress			
8f	heavy duty			
8g	with atleast 4 wheels that is heavy duty			
8h	with atleast a bassinet			
8i	load limit of atleast 150kgs			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
9	Sphygmomanometer			
9a	aneroid			
9b	for pedia			
10	Stethoscope , adult			
10a	length: atleast 27 inches or greater (69cm)			
10b	chestpiece: stainless steel, atleast 87 grams or less, atleast 1.7 inches or greater in diameter			
10c	should be atleast highly sensitive			
10d	chest piece should be atleast stainless steel			
10e	should be atleast with a heavy frame			
10f	should have atleast a perfect spring action			
10g	should atleast be with jointless tube			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
10h	should atleast have a heavy tubing for extra conductivity			
10i	should atleast have extra soft sealing ear knobs for replacement			
11	Pulse Oximeter			
11a	finger-type			
12	Cast Spreader			
12a	with atleast 12 inches in length and with atleast 12 inches blade in cast spreading			
12b	stainless steel			
13	3-Pronged Cast Spreader			
13a	atleast 9 inches in length and with 3 prongs			
13b	stainless steel			

Name Signature of Representative:

TECHNICAL SPECIFICATIONS

Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1(a)(ii) and/or GCC Clause 2.1(a)(ii).

#####				
ITEM NO./REF . NO.	ITEM SPECIFICATION	STATEMENT OF COMPLIANCE	BIDDER'S SPECIFICATIONS	BROCHURE/ UNAMENDED SALES LITERATURE PAGE NO.
14	Bedside Table with Drawer			
14a	Atleast painted white or stainless steel			
14b	with formica top			
14c	tubular with guard rails			
14d	with atleast 1 drawer and 1 lover shelf			
14e	with atleast 4 pieces rubber footing or with wheels			
14f	dimensions should be atleast H: 31" x L: 19" x W: 16"			
14g	should be locally manufactured			

Name Signature of Representative:

To facilitate evaluation of brochure or similar documents supporting bidder's statement of co No./Reference No. that corresponds to the items in the Technical Specification form. See sa

ATS Specifications

Use Category		AC-33iB
Rated Operating Voltage Ue 1		220~400V AC
Rated Operating Frequency		50 Hz /60Hz
Rated Operating Current Ie (Optional) 2		6A, 10A, 16A, 20A, 25A, 3
Switching Control Voltage 3		220V AC
Rated Insulation Voltage Ui		690V AC
Transfer Action Time 4		<3s (preset)
Service Life	Electrical	1,500 Times
	Mechanical	6,000 Times
Rated Short-circuit Making Capacity Icm		7.5kA
Rated Ultimate Breaking Capacity Icu		5kA
Miniature Circuit Breaker Type (Optional)		C or D (Trip characteristic)
Number of Poles (Optional)		3-Pole or 4-Pole
ATS Controller Model (Optional)		Terminal type or Intelligent

Basic parameters of terminal type and intelligent type of ATS

ATS Controller Model (Optional)	Terminal typ
Installation Method	Integrated
Operation Method	Auto & Manu
Monitoring Function	Phase failure del
Conversion Method	Auto switch and a
Firefighting Linkage Control	N/A
Display Function	Signal lamp ind

ATS Dimensions

